

Pre-Bid Queries: "Open Tender for Rate Contract for supply of M/F Contact Assy and Thrust Bearing For 11 KV AB Switch" (Tender no. - TPCODL/ P&S/ 1000001507/ 2024-25)

S No	Page No.	Tender Clause	Content of the Clause	Bidder Query	TPCODL Reply
1	31 of 166	4. GENERAL TECHNICAL REQUIREMENTS- Point No. 20	Size of Moving contacts (Copper Type Electrolytic with silver plated)	Please clarify is it 220mm x50mmx 8mm or 250 mm x 50 mm x 8 mm	Size of Moving contacts (Copper Type Electrolytic with silver plated) (coating thickness not less than 10 microns) shall be 220mmx50mmx8mm for 400A AB Switch and 220mmx35mmx6mm for 200A AB Switch
2	34 of 166	8. TESTS	"Along with the bid, the bidder must submit Type Test Reports on AB switches as per this technical specification, carried out within last five years from the date of opening of techno-commercial bid of the tender from CPRI/ERDA labs only. Other-wise the tender may be rejected."	We request you please consider the Type test certificate issued from Government lab NSIC also.	Accepted