

TPCODL Format for reply of prebid Query / Clarification / Deviation (QCD)						
Tender NIT No.	TPCODL/P&S/1000001511/2024-25					
Tender description:	ONE YEAR RATE CONTRACT OF SUPPLY OF FEEDER PILLAR BOX 400 A & 630 A					
Bidders Name:		Prebid clarification				
Note: The said format to be used only for any Pre-bid Query / Clarifiaction/ Deviation on any of the Tender documents						
S No	Clause No	Page No	Tender Description	Bidder's Query / Clarification	Bidder's Justification	TPCODL Response
1			No Description	Please confirm the dimensions of Panels		Drawing is indicative, Bidder submit the drawing with dimensions as per Type Tested Design to meet the Tender Specifications
2		6	ENG-LV-3009	Pls confirm the MCB Pole - In BOM it is SP & in SLD or Drawing it is DP.		2-pole MCB with 20kA breaking capacity
3				Operating Handle is required for all MCCB's or not. Pls confirm.		Not Required
4		5	ENG-LV-3009	MCB Breaking Capacity is 20kA mentioned in GTP. Pls confirm it is required in the same kA rating or required in 10kA.		MCB Breaking Capacity is 20kA
5		5	ENG-LV-3009	Release of MCCBs - Microprocessor based protection (O/C, S/C & E/F) In Havells Make the MCCB EF Release shall be external, so, pls confirm that the EF Release is required Inbuilt in the MCCB or shall we go with the External EF Release.		Shall be as per specification External E/F module is not acceptable
6		41	ENG-LV-3009	Panel is with Single Door or Double Door, in drawing it is shown onl single door. Pls Confirm	Please confirm	reference picture/drawing are with Outer door open view. Outer door is Double Door arrangement and internal door shall be as per specification picture/drawing. However, Bidder to submit the type tested design during tender
1		34	Enclosure Details	Sheet thickness of box, Body-3mm and Door-2mm	Please confirm	As per specification
2		34	MCCB Incoming and Outgoing	in GTP, No. of Pole of MCCB is 3Pole and in drawing, No. of Pole of Pole is 4Pole	Please confirm	3-pole MCCB
3		35	MCB	Maximum Breaking of 63A DP MCB is 10kA instead of 20kA as per confirmation of MCB Manufacturer	Please confirm	MCB Breaking Capacity is 20kA
4		36	Sr. F	Dimension of Base Channel for Mounting of Box	Please confirm	75x50x5 mm C Channel
5		37	Sr. J	The bus bar sizes shall be 2 layers of required dimension made up of aluminum with Red, Yellow and Blue colour for three phases and black for neutral.	What does it mean. Please confirm	bus bar shall be 1 layer of AL for phase & neutral each. Size of bus bar shall per Clause 4.14 of specification