

3rd set of Consolidate Pre-bid query reply, Open Tender No TPCODL/P&S/1000000723/24-25,SITC Work of E-House at Cuttack, Odisha.

1. Kindly arrange to give the following :
 - a. Layout of site : **PL arrange for a site visit** (Mr Arijit Biswas (TPCODL-NEG Dept, Ph 9477411902)
 - b. SLD with define CT ratio. : **CTR is available in TS**
 - c. Is it mandatory that the dimension of Ehouse will be (L20M x W4.2M x H4.0M).: **Minor Variations are accepted**
 - d. Confirmation that aux trafo must be placed outside the Ehouse. **It will be outside**
 - e. Increase the completion schedule from 120 days to 365 days from PO date. **Shall be as per TS .Contracts to decide**
 - f. 5 year type test clause is not applicable for any equipment if there is no design change in it. **Noted**
 - g. Approve Make list of TPCODL **Shall be shared**
 - h. Technical specs of Aux Trafo **Shall be Shared**
 - i. Technical specs of UPS. **Shall be Shared**
 - j. Overall warranty shall be 24 months from supply & 18 months from ETC which ever is earlier as in tender documents there are different clauses against the warranty. **As per TS**
 - k. Soil Bearing Capacity value. **Not available, Pl plan for a site visit**
 - l. Exact Length of cable trenches. **Not available, Pl plan for a site visit**
 - m. Removal of scada integration work with existing scada or provide us make & model of existing SCADA. **Siemens,Synergy,ABB,Schneider,GE,ALSTOM**
 - n. No stage inspection applicable in this tender. **It will be applicable**
 - o. Clarity where the RTCC panel of Power transformer & NIFPS kept, if same inside the Ehouse then we need dimensions for considering the exact space. **RTCC is not required, TMU is required in 33KV Panel**
 - p. Clarity on scope of below items
 - i. Aux Trafo Foundation work in which scope. **Supplier's scope**
 - ii. SITC with civil work of NIFPS. **Supplier's scope**
 - iii. BOT work in which scope. **Supplier's scope**
 - iv. Fire wall of power trafo in which scope. **Supplier's scope**
 - v. Please define what comes under "All type of Civil Work in switchyard / Transformer yard." **Supplier's scope**
 - vi. Earth resistivity value. **Supplier's scope**
 - vii. Earhpits in which scope. **Supplier's scope**
 - viii. Digital solution, service membership as mentioned in tender BOM is not applicable in this tender **Not Required**