

CENTRALIZED CONTRACTS GROUP**NIT No.: TPCODL / CCG / 2025-26 / 1000002513****Corrigendum- I****NIT No.: TPCODL / CCG / 2025-26 / 1000002513****Rate Contract - Supply of LTCT & HTTV Meter Boxes for TP Odisha DISCOMs****Dated 06th May 2025****Following changes in tender document is made;****1.1 Scope of work (Page No. 4)**

- 2 Bids are invited from interested Bidders to award Rate Contract (RC) for Procurement of LTCT & HTTV Meter Boxes for TP Odisha DISCOMs as mentioned below:

Sl. No	Material Description	UoM	TPCODL	TPNODL	TPSODL	TPWODL	Total
1	SMART LTCT ENERGY METER BOX 100/5A	Nos	1,400	1,000	7,262	450	10,112
2	SMART LTCT ENERGY METER BOX 200/5A	Nos	500	1,000	1,201	100	2,801
3	SMART LTCT ENERGY METER BOX 400/5A	Nos	100	50	122	0	272
4	Three Phase HTTV Meter Box	Nos	100	1,500	690	0	2,290

Pre-bid response & Revised Annexure-1 as attached below;

All other terms and conditions of the above tender shall remain unaltered.

Yours faithfully,
-sd-

HoD - Contracts (TPCODL) & CCG

TPCODL

TP Central Odisha Distribution Limited

TPNODL

TP Northern Odisha Distribution Limited

TPSODL

TP Southern Odisha Distribution Limited

TPWODL

TP Western Odisha Distribution Limited

CENTRALIZED CONTRACTS GROUP**NIT No.: TPCODL / CCG / 2025-26 / 1000002513****ANNEXURE-I****ANNEXURE-I : Price Schedule**

Sr No	Item Description	Unit	Quantity	HSN/ SAC Code	Unit Price (Rs. / Unit)	GST (Rs/ Unit)	All Inclusive Unit Rate (Rs.)	Total All Inclusive Value (Rs.)
1	SMART LTCT ENERGY METER BOX 100/5A	Nos	10,112					
2	SMART LTCT ENERGY METER BOX 200/5A	Nos	2,801					
3	SMART LTCT ENERGY METER BOX 400/5A	Nos	272					
4	Three Phase HTTV Meter Box	Nos	2,290					
Total Package Cost (in Rs.)								

NOTE:

- Prices shall remain Firm.
- The bids will be evaluated commercially on **the line item wise lowest cost** basis.
- The prices mentioned above shall be on FOR basis for all the TPNODL, TPCODL, TPSODL & TPWODL locations.
- Prices shall be inclusive of Transit Insurance/ Packing & Forwarding charges and shall be inclusive of unloading and stacking at any DISCOM site / store locations.
- Issuance of Release Orders (RO) shall be done by respective DISCOMs as per their requirement.
- The material shall be delivered as per the location captured in the Release Order.
- The bidders are advised to quote prices strictly in the above format. Failing to do so, bids are liable for rejection.
- The bidder must fill each and every column of the above format. **Mentioning “extra/inclusive”/other conditions in any of the column may lead for rejection of the price bid.**
- No cutting/ overwriting in the prices is permissible.
- The quantity mentioned above are for evaluation purpose only and may vary as per actual site requirement.

Format for Pre-Bid Queries				
Tender No: TPCODL / CCG / 2024-25 / 1000002513				
Tender Description: Rate Contract - Supply of LTCT & HTTV Meter Boxes for TP Odisha DISCOMs				
Sr. No.	Detailed Reference to Tata Power Technical Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Remarks - Query / Clarification	Tata Power Response
1	2	3	4	5
1	Calendar of Events	Due Date for receipt of Sample for testing as per below address_12.05.2025	Please provide sample of meter for manufacturing of CT 12 pin Zigzag to provide CT sample. However Meter box sample i.e. base ,cover,gland with earthing plate,Rubber cord, 6 no sealable screw with PVC cap can be submitted .Please confirm.	The Sample meter shall be provided in the event of order for terminal arrangement. A proptotype sample to be submitted.
2	Evaluation Criteria	Bidder has to mandatorily quote against each item of Schedule of Items [Annexure I]. Failing to do so, CCG may reject the bids.	We want to quote for item no 1 & 2 because item no 3,4,5 is not in our manufacturing range, please suggest.	The bids will be evaluated commercially on the line item wise, hence may quote as per line item.
	Generel Technical Requirment			
	B	For Current transformers		
	Pin-configuration:	For LTCT Smart Meter Boxes:		
3		100/5A and 200/5A: 12-pin zigzag (dimension should be as per the meter sample provided by TPCODL) 400/5A: 12-pin zigzag (dimension should be as per the meter sample provided by TPCODL)	Please provide sample of meter for manufacturing of CT 12 pin Zigzag	The Sample meter shall be provided in the event of order for terminal arrangement. A proptotype sample to be submitted.
	Generel Construction			
4	SAMPLE	1. Tender Sample: Bidders are required to manufacture two sample boxes as per the TPXODL specification and submit the sample boxes along with the bid for further testing and approval of samples	Please provide sample of meter for manufacturing of CT 12 pin Zigzag to provide CT sample. However Meter box sample i.e. base ,cover,gland with earthing plate,Rubber cord, 6 no sealable screw with PVC cap can be submitted .Please confirm.	The Sample meter shall be provided in the event of order for terminal arrangement. A proptotype sample to be submitted.
	Address of Dispatch:	Meter Testing Lab, Address will be provide during GTP time		Address for Sample submission as per Tender
5		2. Pre-manufacturing Sample: The successful bidder shall submit two prototype samples of meter box at Meter Testing Lab, at location informed by TPXODL during submission time, for further testing and compliance as per specifications and get approval before mass manufacturing	Pre manufacturing sample will be submitted after receipt of sample of Meter to manufacture CT 12 pin Zigzag accordingly.	Noted
6		2mm SS plate should be provided on the base of Meter Box to support Gland and cable	2mm SS plate should be provided on the base of Meter Box to support Gland and cable	Specification to be complied
	GENERAL CONSTRUCTION:5.5 Earthing			
7		At bottom of the enclosure, an Electro Galvanized Earthing plate with minimum 1.2 mm thickness shall be provided with two numbers of earthing nut and bolt of suitable size of SS type for providing earth connection.	At bottom of the enclosure, an Electro Galvanized Earthing plate with minimum 1.2 mm thickness shall be provided with two numbers of earthing nut and bolt of suitable size of SS type for providing earth connection.	Specification to be complied.
8	Cable entry/exit gland size (diameter)	For 100/5A: The SGG brass gland shall be suitable for 4Cx95 sq. mm cable.	clarify the SGG	Single Compression Brass Gland designed for single armoured cable entry and compression.
9		For 200/5A: The SGG brass gland shall be suitable for 4Cx150 sq. mm cable.	clarify the SGG	Single Compression Brass Gland designed for single armoured cable entry and compression.
10		No Technical specification attached with this tender for "BOX TP FOR 3P4W SMART LTCT DT METER"	Please provide the Technical Specification for "BOX TP FOR 3P4W SMART LTCT DT METER"	Line item not required, (As per Corrigendum-1)