

Annexure-IV
Survey Report for Distribution Sub-Station

Section: _____ **Sub Division:** _____ **Division:** _____ **Month:** _____

Sr. No	Survey Date	11 KV Feeder	DSS Name SAP Functional Location Rating (kVA)	Defunct DSS AB Switch (Replacement Required)	Defunct DSS AB Switch (Repair Required)	Damaged HG/DO Fuse (Replacement Required)	Damaged HG/DO Fuse (Repair Required)	Polymeric LA Absent (New Required)	Oil Leakage (Yes/No)	Topping of Oil Required	Silica Gel - Pink (Replacement Required)	Damaged Breather (Replacement Required)	HT /LT jumper - Damaged (Replacement Required)	HT /LT jumper - Damaged (Repair Required)	Arcing Horn- Damaged/Missing (Replacement Required)	Kit Kat Fuse Required	ACB/MCCB/LTDB- Bypassed (Qty. Required)	LT Feeders	Earthing Missing (New Required)	Earthing Damaged (Repair)	DTR Plinth Damaged (Repair)	Vegetation Growth (Cleaning Required)	DSS Fencing- Missing (New Required)	DSS Fencing Damaged (Repair Required)
				Nos.	Nos.	Nos.	Nos.	Nos.	Y/ N	Litre	Kg	Nos.	Nos.	Nos.	Nos.	Nos.	Nos.	Nos.	Nos.	Nos.	Nos.	Y/ N	Nos.	Nos.
1			DSS Name: SAP FL: Rating(kVA):																					
2			DSS Name: SAP FL: Rating(kVA):																					
3			DSS Name: SAP FL: Rating(kVA):																					
4			DSS Name: SAP FL: Rating(kVA):																					
5			DSS Name: SAP FL: Rating(kVA):																					

BA Engineer
(Business Associate)

Section In-Charge
(TPCODL)