

CENTRALIZED CONTRACTS GROUP

NIT No.: TPCODL / CCG / 2026-27 / 1000012648

Corrigendum No. – II**11th Sep'2026****Tender Enquiry No:** - TPCODL/ CCG / 2026-27/ 1000012648**Tender Subject** – Rate Contract for SITC for Indoor Switchgears for TP Odisha DISCOMs.

Clause 1.3: Revised Calendar of Event shall be as follows:

S. No.	Description	Earlier Revised Event Date	Revised Event Date
(a)	Date of sale/ availability of tender documents from Website	17.08.2026	17.08.2026
(b)	Date by which Interested and Eligible Bidder to pay Tender Fee and confirm participation as mentioned in "Procedure to Participate in Tender"	01.09.2026, 18:00 Hours	01.09.2026, 18:00 Hours
(c)	Date & Time of Pre-Bid Meeting (If any)	01.09.2026, 18:00 Hours	01.09.2026, 18:00 Hours
(d)	Due Date of receipt of pre-bid queries by e-mail, if any	03.09.2026, 18:00 Hours	03.09.2026, 18:00 Hours
(e)	Due Date of Posting Consolidated replies to all the pre-bid queries as received	08.09.2026, 18:00 Hours	08.09.2026, 18:00 Hours
(f)	Due date and time of receipt of Bids	12.09.2026, 20:00 Hours	16.09.2026, 20:00 Hours
(g)	Date & Time of opening technical bids	14.09.2026, 11:00 Hours	17.09.2026, 11:00 Hours
(h)	Date & Time of opening of Price of qualified bids	To be notified to the successful bidders	To be notified to the successful bidders

Note: 1. Please refer the attached revised BOQ, to be adhered for submission of price Bid.
2. All other terms & conditions of the tender shall remain same.

Approved By,

Sd/-

Chief– CCG & Engineering

*Property of TPCODL/TPSODL/TPNODL/TPWODL – Not to be reproduced without prior written permission of
TPCODL/TPSODL/TPWODL/TPNODL*

S. NO.	Material Description	UOM	Total Requirement (Revsied)				Supply Part				Service Part			
			TPCODL	TPNODL	TPWODL	Grand Total Req.	Unit Price (Rs.)	GST @18%	Unit Price with GST (Rs.)	Total Amount All Inclusive (Rs.)	Supply Unit Price	Service Unit Prices	All Inclusive Unit Price (Rs.) including GST	Total Amount All Inclusive (Rs.)
1	Lot -1 (11 KV Indoor Switchgear Panel)													
a	11KV 1250A I/C 1250A VCB W CP & RELAY FR PTR	EA	5	7	9	21		0	-	-		0	-	-
b	11KV 1250A BRPT PANEL WITH 3NOS 1PH PT	EA	5	4	4	13		0	-	-		0	-	-
c	11KV 1250A B/C 1250A VCB PANEL W CP & RELAY	EA	5	4	4	13		0	-	-		0	-	-
d	11KV 1250A O/G 630A BKR W CP & RELAY FDR PROT	EA	5	20	22	47		0	-	-		0	-	-
e	11KV 1250A BUS PT PANEL WITH 3NOS 1PH PT	EA	5	3	5	13		0	-	-		0	-	-
f	11KV 1250A ADAPTER PANEL	EA	1	3		4		0	-	-		0	-	-
g	11kv 1250A Indoor 1250A VCB	EA	0	2		2		0	-	-		0	-	-
i	11KV 2000A I/C 2000A VCB W CP & RELAY FR PTR	EA	8			8		0	-	-		0	-	-
j	11KV 2000A BRPT PANEL WITH 3NOS 1PH PT	EA	8			8		0	-	-		0	-	-
k	11KV 2000A B/C 2000A VCB PANEL W CP & RELAY	EA	10			10		0	-	-		0	-	-
l	11KV 2000A O/G 630A VCB W CP & RELAY FDR PROT	EA	60			60		0	-	-		0	-	-
m	11KV 2000A BUS PT PANEL WITH 3NOS 1PH PT	EA	8			8		0	-	-		0	-	-
o	11KV 2000A ADAPTER PANEL	EA	8			8		0	-	-		0	-	-
p	Busbar for Indoor VCB 1250A	M	100	0		100		0	-	-		0	-	-
q	Busbar for Indoor VCB 2000A	M	100	0		100		0	-	-		0	-	-
r	11KV Spare 2000Amp Breaker suitable for Power Transformer without panel	EA	1			1		0	-	-		0	-	-
	Total Amount- All Inclusive (Rs.)- Lot 1									-				-
2	Lot -2 (33 kv Indoor switchgear Panel)		TPCODL	TPNODL	TPWODL	Grand Total Req.	Supply Unit Price	Service Unit Prices	All Inclusive Unit Price (Rs.) including GST	Total Amount All Inclusive (Rs.)	Supply Unit Price	Service Unit Prices	All Inclusive Unit Price (Rs.) including GST	Total Amount All Inclusive (Rs.)
a	33KV Incomer Breaker-1250 A with Control panel & Relay for feeder protection	EA	30	3	2	35		0	-	-		0	-	-
b	Bus Riser cum 33KV 3phase Bus PT Suitable for 1250 A	EA	5	2	1	8		0	-	-		0	-	-
c	Bus Coupler Breaker- 1250 A with Control panel & Relay	EA	10	2	1	13		0	-	-		0	-	-
d	33 kv Outgoing breaker Breaker with 1250Amp suitable for Power Transformer Protection	EA	15	4	2	21		0	-	-		0	-	-
e	33 kv Outgoing Breaker with 1250Amp suitable for Feeder Protection	EA	0	10	2	12		0	-	-		0	-	-
f	33KV 3phase Bus PT Suitable for 1250Amp Bus bar	EA	5	3	1	9		0	-	-		0	-	-
g	33KV 3 Phase 1250A Adapter Panel	EA	3	2		5		0	-	-		0	-	-
h	Breaker Rack in & Rack out Trolley (For not having Floor mounted panel)	EA	0	2		2		0	-	-		0	-	-
i	Bus- bar suitable for 1250Amp for interconnecting between Panels	M	50	2		52		0	-	-		0	-	-
j	33KV Spare 630Amp Breaker suitable for Feeder without panel for 2000Amp Bus	EA	1			1		0	-	-		0	-	-
	Total Amount- All Inclusive (Rs.)- Lot 2									-				-
3	Mandatory Spares (To be supplied as free item along with Indoor Switchgear as per specification)													
a	Trip Coil	EA				01 with each CB								
b	Closing coil	EA				01 with each CB								
c	Spring charging motor	EA				01 upto 5 nos. CB								
d	Vacuum interrupter	EA				01 upto 5 nos. CB								
e	T-N-C Switch	EA				01 with each CB								
f	Local / remote selector switch	EA				01 with each CB								
g	Tulip/ Finger contact	EA				01 upto 5 nos. CB								
h	Indication lamps	EA				1 set upto 5 nos. CB (R,Y,B,ON,Off,Trip)								
i	Auxiliary switches	EA				1 set upto 5 nos. CB								
j	LED for cable charge indication	EA				1 set upto 5 nos. CB								