

Reply of Pre-Bid Query / Clarification

Tender No : TPCODL/P&S/2026-27/1000011967

Tender Name: Rate Contract for Civil Maintenance across TPCODL for Two Years

Sr. No.	Detailed Reference to TPCODL Tender Document. Please specify Document No / Clause No / Page No	Description as per Bid Document	Bidder Query	TPCODL Response
1	2	3	4	5
1	Annx. - I, SI No - 05	P & L 225 or 300 mm thk dry rubble soling	Pl. consider to remove this item as there is a restriction for availability of Stone	Soling is not a regular practice, it is required in special cases where soil bearing is not fit for foundation, so it cannot be removed
2	Annx. - I	RCC 1:1:2, Brick work, Plastering etc	Separate item from plinth level to 3mtr and above 3 mtr should be added	As per CPWD norms from ground floor level to Fifth floor level (up to a height of 15 m), the rates for concrete, plaster and brickwork are same
4	GCC, CI - 08 SECURITY CUM PERFORMANCE DEPOSIT	(a) 5% of the PO value if purchase order value is more than Rs 5 Crores. (b) 10% of the PO value if purchase order value is less than Rs 5 Crores.	Is there any relaxation for Odisha MSMEs	As per Clause 7.0 (Post Award Contract Administration), PBG amounting to 5% of the RC value for Non-Odisha MSME or 1.25% of the RC value for Odisha MSME.
5	Appendix 3: CSM F3 - Safety Category Qualification form	(ISO certificates to be issued from reputed accreditation agencies specified by Tata Power)	Pl. specify the agencies	Any agency who has got the license from the concerned Accreditation body.
6	Qualification Criteria	Order copies along with completion certificate duly signed by competent authority have to be submitted as documentary proof.	As existing vendor of TPCODL, is it required?	Tender conditions stand, all the documents are required as per the tender qualifying criteria
7	Performance	BA shall submit at least one-year Performance Certificate by any DISCOMs / PSUs / Reputed Companies for similar nature of work or higher rating of work experience. Work against these issued certificates should be completed in last 5 years from the date of bid submission. Performance certificate to be submitted in this regard. In case the bidder has a previous association with Tata Power Group of Discoms for similar services, the performance feedback for that bidder by respective Discoms shall only be considered.	As existing vendor of TPCODL, is it required?	Tender conditions stand, all the documents are required as per the tender qualifying criteria