

Format No. –
Revision No. –
Eff. Date –

CORRIGENDUM – 04
Tender no. TPCODL/P&S/2026-27/1000009868

Tender for “Rate Contract for Maintenance of HT & LT Network at TPCODL for 3 Years”

Subject: Regarding amendment in Tools and Tackles

1. Make of below material (under 11 kV tool) has been changed.

Category	Item Description	Requirement	Existing Make List	Revised Make List
Testing Instruments	Non-Contact type LT line tester.	1 per Skilled person	Fluke, Silicon waves	Revised Make - Taparia or equivalent

2. Below Materials needs to be removed from the both T & Ps list of 33kV & 11 kV as this is attributing huge cost and may not be required all the time.

For safe Conductor Stringing (learning from LWDC) - Suggested Additional tools and tackles				
109	T&Ps	Pulley for arrangement of stringing activities of lifting of tools (spanner, sling, pulley, ropes etc.) - SWL 1T	1 per division	
110	T&Ps	SWL of swivel joint – 3 T		
111	T&Ps	Socket single end SWL- 3T as per DOG, Rabbit, Panther conductor		
112	T&Ps	Automatic clamp with arrangement of remove from ground level by rope		
113	T&Ps	Hydraulic conductor cutter		
114	T&Ps	Single roller SWL 3T or Twin roller		
115	T&Ps	Open pulley SWL- 3T		
116	T&Ps	D-shackle SWL-3T, 5T		
117	T&Ps	Dynamometer 0 to 5T minimum		
118	T&Ps	Sling SWL- 3T and more SWL for		
119	T&Ps	Turn table SWL 10T max.		

In place of the above T&P, please consider the following clause.

“Any Slings activity shall be carried out using mechanized tools such Trifor machine, Pulley, Winch, Tensioner, Pilot Clamps etc. Makeshift arrangements like pulling through the tractor are strictly prohibited”.

All other terms and conditions of the original tender shall remain unaltered.

Dated: 09.07.2026

Yours faithfully,
-sd-
Chief CCG & Engineering