

Responses to the Prbid Queries / Clarifications				
Tender description: Supply and Installation of 11kV, LT lines and DT Substations for providing power supply to Un-electrified households under PM-AJAY & DA-JGUA scheme and Additional households under BGJY scheme on turnkey basis. Tender No- TPCODL/P&S/2026-27/ 1000012608				
Sl No	Clause No	Tender Description	Bidder's Query / Clarification	TPCODL Response
1	1.3 Calendar of Events	(f) Last date and time of submission of Bids through ARIBA E-Tender Portal 05.09.2026; 22:00 Hours	The bidder is a leading service provider to AMISPs across various states in India and has extensive experience in executing similar works, including the installation of 11kV/LT lines and DT substations. We are executing similar projects with HPSEBL, Shimla, KSCL and DSCL under Smart City Projects. To thoroughly study the tender requirements and prepare a competitive bid, we require some additional time. Therefore, we kindly request you to extend the bid submission date from 05.09.2026 to 21.09.2026.	Tender clause stand.
2	1.7 Qualification Criteria: Technical Qualification	The bidder must have successfully executed 11 kV or higher voltage grade overhead line of minimum 25 Kms and 11/0.4 KV or higher voltage grade DT Sub Station of minimum 20 Nos on EPC Contract / Turnkey Contract basis, in any utility/companies during Last Five Years preceding to the date of NIT.	The bidder has already executed similar works as mentioned in the tender through its subsidiary, Himachal Energy Private Limited (certificate attached). In addition, we have successfully executed similar works under Smart City Projects in Dharamshala, Karnal and Bhopal, including pole foundations, LT cable supply & installation, LT connection, Panel Supply & installation, and other related electrical works. We are therefore sharing the relevant work completion/experience certificates for your reference and consideration.	The bid shall be evaluated only after bid submission as per the tender's eligibility criteria.
3	1.7 Qualification Criteria: Technical Qualification	The bidder must have successfully executed 11 kV or higher voltage grade overhead line of minimum 25 Kms and 11/0.4 KV or higher voltage grade DT Sub Station of minimum 20 Nos on EPC Contract / Turnkey Contract basis, in any utility/companies during Last Five Years preceding to the date of NIT.	We request to consider and accept similar experience of past 10 years in place last 5 years.	Tender clause stand.
4	7.1.7 Payment Terms:16	Clause 7.1.7 depicts payment on: A. Mobilization Advance:10%, B. Supply: 80% & 20%, C. Erection: 90% & 10% A. Mobilization Advance:5%, B. Mobilization Advance:10%, C.50% , D.15%	We request to confirm, which clause to be applicable as Payment Terms out of two different clauses.	The payment terms mentioned at "Special Conditions of Contract CI No- 7.1.7 shall be applicable.
5			We request to confirm whether experience of subsidiary company is considerable to parent company for participation in this tender	Experience of the subsidiary company shall not be considered. Documents of the bidder in its own name shall be evaluated.
6	Schedule of Items ANNEXURE I		Detailed BOQ/material list with quantities and specifications	The detailed price schedule / BOM has already been provided in the Tender document at Page no- 36/609
7	Approved Make			Approved makes for brought-out items shall be considered as per the vendor list provided in the tender document and/or the latest list of approved manufacturers available on the TPCODL website.

Sl No	Clause No	Tender Description	Bidder's Query / Clarification	TPCODL Response
8	Statutory compliances			The contract being activity-based, any liability arising out of statutory compliances, including gratuity, PF, ESIC, etc shall be the sole and exclusive responsibility of the BA. Accordingly, the Organization shall not, under any circumstances, be held liable or responsible for any statutory compliances or obligations in respect of the BA's personnel.