

Tender Ref: TPCODL/CCG/2026-27/ 1000009957

Rate Contract for Supply of ACDB & DCDB of various ratings at TP ODISHA DISCOMS for 1 year.

Sl. No.	Tender Reference (Document name/Page no./Clause no./Clause name)	Pre-Bid Query raised by Bidder	TP Odisha Discom
1	SPECIFICATION FOR DCDB(PAGE NO 5/S.I NO 22)	DOUBBLE POLE MCCB NOT AVAILABLE IN MICROPROCESSOR RELEASE FOR 24/48V DC (please confirm 24/28 volts is control voltage or oprational voltage)	To be decided during technical evaluation
2	SPECIFICATION FOR ACDB(PAGE NO 5/S.I NO 24 ,25,26)	DC MCB DP 10 KA SUITABLE FOR 24/48 V DC NOT AVAILABLE	Kindly adhere to Technical Specification
3	SPECIFICATION FOR DCDB(PAGE NO 5/S.I NO 30)	UNDER VOLTAGE ,OVERVOLTAGE , DC EARTH LEKAGE PROTECTION REQUIRED IN A SINGLE RELAY OR WE HAVE TO USE DIFFERENT RELAY FOR EACH PROTECION	Kindly adhere to Technical Specification
4	SPECIFICATION FOR DCDB(PAGE NO 5/S.I NO 29)	220 V AC AUXILARY SUPPLY REQUIRED FOR PANEL ,SPACE HAETOR &THERMOSTAT	Noted.
5	Make of Switchgear (MCCB)	Please include HPL make as we are manufacturer of both types AC & DC MCCB's	Can be accepted subjected to sub ission of complete type test report as per IS/IEC.