

Tender Reference No :		TPCODL / CCG /26-27 /1000009919																	
Tender Name :		Rate Contract - Supply of CT-PT Junction Boxes at TP DISCOMs for One Year																	
Sl. No.	Tender Reference (Document name/Page no./Clause no./Clause name)	Pre-Bid Query raised by Bidder	Responses																
1	Technical specification for CT & PT Junction box /Pg-10/Drawing	3 nos of PVC Cable duct and 2 Nos of neutral bus bar are shown in the sample drawing. Please mention the size of PVC Cable duct and Neutral bus bar.	PVC cable duct : 25x45x245 mm Length : 4 No.s are required. Aluminium Busbar: 25x5x200 mm Length: 2 No.s are required.																
2	Technical specification for CT & PT Junction box /Pg-6/Marking	Regarding the marking on the SS plate, can we consider an Aluminium plate instead, as it will be better because SS plates typically come with a high-gloss, mirror-finish surface. Due to this high reflectivity, engraved or etched markings on an SS surface can suffer from poor contrast, making them difficult to read under outdoor sunlight. Over time, environmental exposure can easily omit or fade the markings on a plain SS surface. Please confirm.	Stainless steel with engraved name plates as per tendered specifications are required.																
3	Technical specification for CT & PT Junction box /Pg-11/Drawing	With reference to the technical specifications and the provided gland plate drawing, we see a requirement for 4 nos. of 25 mm holes and 4 nos. of 19 mm holes. Kindly clarify if this specified hole configuration is final for manufacturing, or if there will be any changes to the hole sizes and quantities before project execution.	<table border="1"> <thead> <tr> <th>Holes</th><th>TPSODL</th><th>TPCODL</th><th>TPNODL</th><th>TPWODL</th></tr> </thead> <tbody> <tr> <td>19mm</td><td>12</td><td>6</td><td>3</td><td>6</td></tr> <tr> <td>25 mm</td><td>3</td><td>3</td><td>2</td><td>3</td></tr> </tbody> </table>		Holes	TPSODL	TPCODL	TPNODL	TPWODL	19mm	12	6	3	6	25 mm	3	3	2	3
Holes	TPSODL	TPCODL	TPNODL	TPWODL															
19mm	12	6	3	6															
25 mm	3	3	2	3															
4	Technical specification for CT & PT Junction box /Pg-4 /General Technical requirements/Point-12	Kindly confirm if Elmex CATD M4 Terminal Blocks can be considered and accepted as per the tender requirements or not.	Disconnecting type TBs of specified makes in tender specifications are accepted. Elemex CATD M4 is preferred.																