

		RESPONSE TO THE PREBID QUERY	
Tender No. <b>TPCODL/P&amp;S/1000008965/2026-27</b>			
Tender description: .Rate Contract for Supply of Hardware Fittings			
Note: The said format to be used only for any Pre-bid Query / Clarifiaction/ Deviation on any of the Tender documents			
sl no.	Bidder's Query / Clarification	Bidder's Justification	TPCODL Response
1	in TS no ENG-GEN-4028 in GTP for 90 KN B&S hardware 4 bolted required Ball eye and socket eye for 20 mm	For 90 kN hardware we use 16 mm Ball eye and scoket eye.we have type test report and in tata power it is general practice	Noted & Accepted. For 90 kN (4 Bolted) B&S type Hardware required <b>Ball Eye &amp; Socket Eye shall be 16 mm Forged Steel.</b>