

2nd Prebid response

NIT- TPCODL/P&S/1000008961/26-27, TROLLEY MOUNTED, S/S 500 KVA DT.

BIDDERS QUERY	TPCODL RESPONSE
kindly clarify which option to quote In page 34 its been mentioned Option - 1 & Option - 2	Bidder should quote for Option-1 only. HV Side - 11kV LBS & HRC Fuse Panel DTR - Conventional 500kVA/250kVA Cu. Winding Oil Type DT LV side - 2 nos. MCCB in LV Distribution Box